

School Environmental Inspection Summary For 2007 - 2008

School Name: Gardner Elementary School
Address: 30 Athol Street, Allston, MA 02134
Date of inspection: 11/20/2007
Inspector(s): Heather Strauss
Has Written IPM Program in Office: Y
Date of Last IPM Activity Logged: 10/12/2007
Number of areas: 37
Number of areas inspected: 36
Source of Drinking Water: Bottled Water

Environmental Issue	Number of areas with the Condition	Percentage of areas inspected with the condition
Leaks/Water Stains	2	5.4%
Visible Mold Growth	0	0.0%
Overt Pest Sign	0	0.0%
Clutter	4	10.8%
Dust	0	0.0%
Cleaning needed	0	0.0%
Repairs needed	11	29.7%
Improper Chemical Storage	0	0.0%

	Normal Indoor Range	Average outside the school	Average inside the school
CO ₂ level	375 – 1,000 ppm	400	777
CO level	0 - 9 ppm	0	0
PM ₁₀ (airborne dust) level	0.00 - .05 mg/m ³	0.014	0.024
VOC level	150 – 300 ppb	0	0
Temperature	68 – 75 degrees	36	74.2

Bathrooms: Items/Conditions	
Number of bathrooms inspected:	4
Total number of urinals	10
Number of non-functioning urinals	0
Total number of toilets	19
Number of non-functioning toilets	0
Number with bad stall doors	0
Number of toilets without toilet paper	0
Number of bathroom sinks	11
Number of broken sinks	0
Number of soap dispensers	10
Number of broken dispensers	1
Percent of bathrooms without adequate soap	0.0%
Percent of bathrooms without paper towels	0.0%

